

Construction Inspection Summary Report**Duchesne County__ School District**

(For all projects exceeding \$100,000)

Inspections for Month of:	April	Year: 2006	USOE Project Number:
Job Name/Description:	Address:		Form Completed by: Fred Christensen, ICBO
New Roosevelt Junior High School	Roosevelt, Utah		
			Title: SDBO, Business Administrator
General Contractor: CMGC: HUGHS CONSTRUCTION~ ICBO INSPECTOR, JERRY REAGAN			
ARCHITECT: ERIN YOUNGBERG NAYLOR WENTWORTH LUND ARCHITECTS. ~ Site Representative ~ ERIN YOUNGBERG, Architect			
Total Number of Inspections for Period:			
Building/Architectural	Notes	Structural	Notes
[] Fireproof		[] Footings	
[] Waterproof		[X] Formwork	
[] Underground		[] Foundation	
[] Drywall/Paint		[X] Rebar	
[] Roofing		[X] Steel Framing	
[] Compaction		[X] Columns	
[] Final Grade		[X] Steel	
[] Accessibility		[X] Masonry	
[] Sheet rock		[] Decking	
[] Ceiling Grid		[] Bolts/Welds	
[]		[] Brick Veneer	
[]		[X] Concrete	
Mechanical	Notes	Plumbing	Notes
[X] Rough--Above Ground		[] Rough Underground	
[] Rough--Under Ground		[] Underground Gas	
[] Ductwork		[X] Above Rough	
[] Insulation		[X] Sewer	
[X] Air Tests		[X] Culinary	
[] Equipment		[] Roof Drain	
[] Refrigeration		[X] Testing	
[] Controls		[] Finish	
[] Hydronic Test		[] Fire Sprinkler--Rough	
[]		[] Fire Sprinkler--Finish	
[]		[]	
Electrical	Notes	Other/Special	Notes
[] Rough Underground		[] Boiler	
[X] Rough Electrical		[] Pressure Vessels	
[] Fire Alarm		[] Elevators	
[] Sound		[] Deck Framing	
[] Computer Cable		[X] Tilt Up Walls	
[] Telephone Cable		[]	
[] Security/Energy		[]	
[X] Rough Above Ground		[]	
[] Power Service		[]	
[] Panels		[]	
[]		[]	

Faxed Date:

USOE Jane Zang

801-538-7729

Building Official Signature: _____

Date: _____

Copies to: Local Jurisdiction
USOE

I:\DATA\EXCEL\BUILDING\Duchesne_2309_0406

Construction Inspection Summary Report

Duchesne County School District

(For all projects exceeding \$100,000)

Inspections for Month of:		May	Year: 2006	USOE Project Number:	
Job Name/Description:		Address:		Form Completed by: Fred Christensen, ICC	
New Roosevelt Junior High School		Roosevelt, Utah		Title: President / CB&A	
				State License Number: 263980-5601	
				Discipline:	
General Contractor:		CMGC: HUGHS CONSTRUCTION			
ARCHITECT: ERIN YOUNGBERG NAYLOR WENTWORTH LUND ARCHITECTS. ~ Site Representative ~ ERIN YOUNGBERG, Architect					
Total Number of Inspections for Period:					
Building/Architectural		Notes	Structural		Notes
[]	Fireproof		[X]	Footings	
[]	Waterproof		[X]	Formwork	
[]	Underground		[X]	Foundation	
[]	Drywall/Paint		[X]	Rebar	
[X]	Roofing		[X]	Framing	
[]	Compaction		[X]	Columns	
[]	Final Grade		[X]	Steel	
[]	Accessibility		[X]	Masonry	
[]			[]	Decking	
[]			[X]	Bolts/Welds	
[]			[]		
[]			[]		
Mechanical		Notes	Plumbing		Notes
[X]	Rough--Above Ground		[X]	Rough Underground	
[]	Rough--Under Ground		[]	Underground Gas	
[X]	Ductwork		[X]	Above Rough	
[X]	Insulation		[X]	Sewer	
[X]	Air Tests		[X]	Culinary	
[X]	Equipment		[X]	Roof Drain	
[]	Refrigeration		[X]	Testing	
[]	Controls		[]	Finish	
[]	Hydronic Test		[]	Fire Sprinkler--Rough	
[]			[]	Fire Sprinkler--Finish	
[]			[]		
Electrical		Notes	Other/Special		Notes
[X]	Rough Underground		[]	Boiler	
[]	Finish Electrical		[]	Pressure Vessels	
[]	Fire Alarm		[]	Elevators	
[]	Sound		[]		
[]	Computer Cable		[]		
[]	Telephone Cable		[]		
[]	Security/Energy		[]		
[]	Rough Above Ground		[]		
[]	Power Service		[]		

Building Official Signature: _____ Tony Grant

June 2 06

Please e-mail this form to Jane Z. Zhang: jane.zhang@schools.utah.gov.

Building Development

Duchesne County
PO Box 446 - 90 East 100 South
Certification

Property Address Roosevelt Junior High School • Roosevelt, Utah 84066

Contractor Hughes Construction

Owner Duchesne County School District

Inspection <div style="display: flex; justify-content: space-between;"> <div style="width: 20%;"> Type <input checked="" type="checkbox"/> COMM <input type="checkbox"/> RES </div> <div style="width: 20%;"> <input type="checkbox"/> BLDG <input type="checkbox"/> MECH <input type="checkbox"/> SPECIAL </div> <div style="width: 20%;"> <input type="checkbox"/> ELEC <input type="checkbox"/> <input type="checkbox"/> </div> <div style="width: 20%;"> <input type="checkbox"/> PLBG <input type="checkbox"/> PREINSPECTION <input type="checkbox"/> EXCAVATION </div> </div>			
RESULTS OF INSPECTION	<input checked="" type="checkbox"/> WORK APPROVED	Stage <input checked="" type="checkbox"/> Partial <input type="checkbox"/> Complete	
	<input type="checkbox"/> WORK IN VIOLATION	<input type="checkbox"/> Do Not proceed with work <input type="checkbox"/> Make necessary corrections <input type="checkbox"/> Work must be complete for reinspection within	
	<input type="checkbox"/> UNABLE TO MAKE INSPECTION		
	<input type="checkbox"/> Issued Stop Order <input type="checkbox"/> Reinspection Required		
<div style="display: flex; justify-content: space-between;"> <div> <input type="checkbox"/> Cannot locate <input type="checkbox"/> Building locked </div> <div> <input type="checkbox"/> Double Fee <input type="checkbox"/> Reinspection Fee Required </div> </div>			

COMMENTS

1- Footing inspection: Forms and steel reinforcement installed

concrete placement inspection.

2- Steel reinforcement passed inspection as per drawings S

3- Embeds for tilt was installed as per drawing S.502, inspe

4- Dowels for foundation walls installed as per drawings S

5- Area of footings located between grid 11-6 and 11-8, e

6- All above items inspected, also as per specs sec. 03100

7- Special inspection company took concrete samples, slur

Note: Concrete truck 1.5 hours late.

Development & Construction

Deer Creek County School District

1 • Duchesne, Utah 84021 • (435) 738-1252

Certificate of Inspection

Job No. _____

_____ Date May 31, 2005

_____ Time 1:00 Pm

Reason for Inspection			
<input checked="" type="checkbox"/> CALLED	<input type="checkbox"/> ROUTINE	<input type="checkbox"/> COMPLAINT	<input type="checkbox"/> PICK UP
<input type="checkbox"/> footing	<input type="checkbox"/> underground	<input checked="" type="checkbox"/> concrete	<input type="checkbox"/> power to panel
<input type="checkbox"/> foundation	<input type="checkbox"/> rough	<input type="checkbox"/> steel	<input type="checkbox"/> ch. 70
<input type="checkbox"/> frame	<input type="checkbox"/> pre-final	<input type="checkbox"/> masonry	<input type="checkbox"/> sheet rock
<input type="checkbox"/> insulation	<input type="checkbox"/> occupancy	<input type="checkbox"/> progress	<input type="checkbox"/>

work _____
 ions _____
 ed with a call _____
 1 _____ days.

☐ prior violations not corrected
☐ prior violations corrected
☐ items listed below will be inspected at next regulation inspection.

the property. _____
 ed. _____

☐ Admittance refused.
☐ Approved plans not available.

hired _____

called as per drawings, inspected as per S.000, S.5001, and S.501. Plus _____

S.502.

ection passed.

S.502, inspection passed.

east footing outside south footing.

pictures taken at this area showing steel, forms and concrete placement.

mp and air tests.

Signed Jerry Reagan Christensen Brothers and Associates, Inc.
Building Inspector

Construction Inspection Summary Report

Duchesne County School District

(For all projects exceeding \$100,000)

Inspections for Month of:		June	Year: 2006	USOE Project Number:	
Job Name/Description:		Address:		Form Completed by: Fred Christensen, ICC	
New Roosevelt Junior High School		Roosevelt, Utah		Title: President / CB&A	
				State License Number: 263980-5601	
				Discipline:	
General Contractor:		CMGC: HUGHS CONSTRUCTION			
ARCHITECT: ERIN YOUNGBERG NAYLOR WENTWORTH LUND ARCHITECTS. ~ Site Representative ~ ERIN YOUNGBERG, Architect					
Total Number of Inspections for Period:					
Building/Architectural		Notes	Structural		Notes
[]	Fireproof		[X]	Footings	
[]	Waterproof		[X]	Formwork	
[]	Underground		[X]	Foundation	
[]	Drywall/Paint		[X]	Rebar	
[X]	Roofing		[X]	Framing	
[]	Compaction		[X]	Columns	
[]	Final Grade		[X]	Steel	
[]	Accessibility		[X]	Masonry	
[]			[]	Decking	
[]			[X]	Bolts/Welds	
[]			[]		
[]			[]		
Mechanical		Notes	Plumbing		Notes
[X]	Rough--Above Ground		[X]	Rough Underground	
[]	Rough--Under Ground		[]	Underground Gas	
[X]	Ductwork		[X]	Above Rough	
[X]	Insulation		[X]	Sewer	
[X]	Air Tests		[X]	Culinary	
[X]	Equipment		[X]	Roof Drain	
[]	Refrigeration		[X]	Testing	
[]	Controls		[]	Finish	
[]	Hydronic Test		[]	Fire Sprinkler--Rough	
[]			[]	Fire Sprinkler--Finish	
[]			[]		
Electrical		Notes	Other/Special		Notes
[X]	Rough Underground		[]	Boiler	
[]	Finish Electrical		[]	Pressure Vessels	
[]	Fire Alarm		[]	Elevators	
[]	Sound		[]		
[]	Computer Cable		[]		
[]	Telephone Cable		[]		
[]	Security/Energy		[]		
[]	Rough Above Ground		[]		
[]	Power Service		[]		

Building Official Signature: _____ Date: _____

Please e-mail this form to Jane Z. Zhang: jane.zhang@schools.utah.gov.

Construction Inspection Summary Report**Duchesne county_School District**

(For all projects exceeding \$100,000)

Inspections for Month of: July		Year: 2005		USOE Project Number:	
Job Name/Description:		Address:		Form Completed by: Tony Grant	
Roosevelt JR High School		Roosevelt ,UT 84066		Inspection by: Jerry Reagan	
				Title: Building Official	
General Contractor:		Hughes Construction			
Total Number of Inspections for Period: 9 Inspection sheets with 50 line items					
Building/Architectural		Notes		Structural	
[] Fireproof				[x] Footings	
[] Waterproof				[x] Formwork	
[x] Underground				[x] Foundation	
[] Drywall/Paint				[x] Rebar	
[] Roofing				[] Framing	
[] Compaction				[] Columns	
[] Final Grade				[] Steel	
[] Accessibility				[x] Masonry	
[]				[] Decking	
[]				[] Bolts/Welds	
[]				[x] Geothermal drilling	
[]				[]	
Mechanical		Notes		Plumbing	
[] Rough--Above Ground				[x] Rough Underground	
[] Rough--Under Ground				[] Underground Gas	
[] Ductwork				[] Above Rough	
[] Insulation				[] Sewer	
[] Air Tests				[] Culinary	
[] Equipment				[] Roof Drain	
[] Refrigeration				[] Testing	
[] Controls				[] Finish	
[] Hydronic Test				[] Fire Sprinkler--Rough	
[]				[] Fire Sprinkler--Finish	
[]				[]	
Electrical		Notes		Other/Special	
[x] Rough Underground				[] Boiler	
[] Finish Electrical				[] Pressure Vessels	
[] Fire Alarm				[] Elevators	
[] Sound				[]	
[] Computer Cable				[]	
[] Telephone Cable				[]	
[] Security/Energy				[]	
[x] Rough Above Ground				[]	
[] Power Service				[]	

Building Official Signature: _____ Tony Grant

Date: July 28, 2005

Please e-mail this form to Jane Z. Zhang: jane.zhang@schools.utah.gov.